

RESPONSE TO BIDDERS' QUESTIONS NO. 2¹
SOLID WASTE PERMIT #498 FINAL COVER SYSTEM CONSTRUCTION
BRISTOL INTEGRATED SOLID WASTE MANAGEMENT FACILITY
BRISTOL, VIRGINIA

September 22, 2023

The following is a list of questions pertaining to the subject project that have been submitted by Bidders following the issuance of Addendum 1. Questions² are in bold type with Engineer's response following each question in italics.

- 1. The following question references the final cover system erosion control layer and vegetative cover layer. Will SCS separately certify the thickness of the 18-inch erosion control layer and the 6-inch vegetative cover layer, or will SCS only certify the total 24-inch minimum thickness of the cover soils?**

SCS will only certify the total 24-inch minimum thickness of the cover soils. It is the Contractor's responsibility to provide adequate material for the vegetative cover layer in order to establish vegetation.

¹ This Response to Bidders' Questions is not intended to constitute a revision to the Bid Documents.

² Questions may be edited for clarity and similar questions may be combined.

